

City of Las Vegas Code and Interpretation

AMEND: 27

DATE: December 19, 2008

CODE: 2006 IBC ☐ 2005 NEC ☐ Local Amendments ☐
 2006 IRC ☐ 2006 UMC ☒ POOL CODE ☐
 2006 IECC ☐ 2006 UPC ☐ MISC. ☐ Admin Code

CODE SECTION: UMC 402.3 Mechanical ventilation

TOPIC: Plan review stamp for outside ventilating air.

PURPOSE/REASON: Have plan check stamp “outside ventilating air required with installation of an FAU” on shell building plans.

INTERPRETATION: Accepted as proposed.

Approved: Chris Knight, CBO